











Size: DN 1/4" to 2"
Ends: Threaded BSP

Min Temperature : -20°C **Max Temperature :** + 180°C

Max Pressure: 40 Bars

Specifications: Anti blow-out stem

Locking device 1 piece type

Materials: Stainless steel





SPECIFICATIONS:


Reduced bore Anti blow-out stem Locking device Solid ball 1 piece type

USE:

Chemical and pharmaceutical industries, petrochemical industries, hydraulic installation, compressed air Min and max Temperature Ts: -20°C to + 180°C Max Pressure Ps: 40 bars (see graph)

PRESSURE / TEMPERATURE GRAPH (STEAM EXCLUDED) :

PRESSURE








RANGE:

Stainless steel DN 1/4" to DN 2"

ENDS:

Female / female threaded BSP




Item	Designation	Materials			
1	Body	ASTM A351 CF8M			
2	Ball	ASTM A351 CF8M			
3	Stem	SS 316			
4	Insert	SS 316			
5	Seat	PTFE			
6	Stem packing	PTFE			
7	Thrust washer	PTFE			
8	Gland	SS 304			
9	Handle	SS 304			
10	Locking device	SS 304			
11	Handle cover	Plastic			
12	Handle washer	SS 304			
13	Handle nut	SS 304			







SIZE (in mm):



Stem size :





Ref.	DN	1/4"	3/8"	1/2"	3/4"	1"	1"1/4	1"1/2	2"
708	ØΡ	5	6.8	9	12.5	16	20	25	32
	L	39	44	56.5	58.5	71	78	83	100
	Ø D	6	6	8	8	8	8	8	8
	E	65	65	96	96	101	101	135	135
	Н	32	35	45	48	56	61	70	76
	L1	9.5	10.5	16	15	17	19	20	23
	L2	9.5	10.5	14	15	17	19	19	23
	W on flat	17	21	25	32	38	48	53	66
	С	3	4	5	5	6	6	8	8
	ØΥ	4,6	6	7	7	9	9	11.5	11.5
	Weight (Kg)	0.06	0.1	0.19	0.26	0.41	0.62	0.84	1.33





TORQUE VALUES (in Nm without safety coefficient):

DN	1/4"	3/8"	1/2"	3/4"	1"	1"1/4	1"1/2	2"
TORQUE (Nm)	2	2	3	4	5	6	8	10

STANDARDS:

Fabrication according to ISO 9001: 2008

DIRECTIVE 97/23/CE: CE N° 0035

Risk Category III Module H

Pressure tests according to ISO 5208, Range A

Threaded cylindrical BSP ends according to ISO 228-1

ADVICE: Our opinion and our advice are not guaranteed and SFERACO shall not be liable for the consequences of damages. The customer must check the right choice of the products with the real service conditions.

INSTALLATION AND MAINTENANCE

BEFORE INSTALLATION:

Pipe-line must be cleaned and free from residual of weldings,rubbish,shaving and every kind of extraneous materials. Pipe-line must be perfectly aligned and their support properly dimensioned so that there's no external constraint.

Please use the right product according to the services conditions to seal the valve. Use the right bolt tightening so that the ends won't be damaged.

CLEANING AND TESTS

Keep closed the valves during the cleaning operation so that there's no impurities between the ball and the body.

Tests under pressure must be done with a cleaned pipe-line.

Open partially the valve for tests. Pressure test do not exceed the valve specifications according to EN 12266-1.

MAITENANCE

It's recommended to operate the valve twice (open and close) 1 to 2 times per year.

When intervention on the valve, be sure there's no pressure in the pipe-line, there's no fluid in it, and that it is isolated. The temperature must be low enough to operate without risks. If there's a corrosive fluid, inert installation before intervention.

When the valve is under pressure :

If there's a leakage at the packing, tighten it slightly so that the leakage disappears.



