

WAFER SWING CHECK VALVE



- Size :** DN 40 to 600
- Ends :** Between flanges PN10/16
- Min Temperature :** - 10°C
- Max Temperature :** +80°C in NBR, 110°C in EPDM , 180°C in FKM
- Max Pressure :** 16 Bars up to DN200 (10 bars over)
- Specifications :** Wafer swing check valve
Vertical or horizontal position
Between flanges type

Materials : Carbon steel or Stainless steel

WAFER SWING CHECK VALVE


SPECIFICATIONS :

Wafer swing check valve
Vertical position with ascendant fluid or horizontal position (respect the flow direction indicated by the arrow)
Between flanges PN10/16
With hoisting eye
Short length
Economical solution
Monobloc disc and stem for a better mechanical strength
Integrated body gasket

USE :

Heating, water distribution and watering
Min and max Temperature Ts : - 10°C to + 80°C for carbon steel NBR type **Ref.351**
Min and max Temperature Ts : - 10°C to + 110°C for carbon steel EPDM type **Ref.364**
Min and max Temperature Ts : - 10°C to + 180°C for stainless steel FKM type **Ref.365**
Max Pressure Ps : 16 bars up to DN 200 included and 10 bars over
Do not use with pulsatory speed
Max Speed : 3 M. / Sec.


HEAD LOSS GRAPH :



WAFER SWING CHECK VALVE

RANGE :


Galvanized carbon steel body with NBR gasket between flanges PN16 **Ref. 351** DN40 to DN 300
 Galvanized carbon steel body with EPDM gasket between flanges PN16 **Ref. 364** DN40 to DN 600
 Stainless steel body with FKM gasket between flanges PN16 **Ref. 365** DN40 to DN 600
 Stainless steel body with FKM gasket between flanges PN10 **Ref. 365401 and 365451** DN400 to DN 450

MATERIALS :


Item	Designation	Materials 351	Materials 364	Materials 365
1	Body	Carbon steel with chromium plated Q235	Carbon steel with chromium plated Q235	ASTM A351 CF8M
2	Disc	Carbon steel with chromium plated Q235	Carbon steel with chromium plated Q235	ASTM A351 CF8M
3	Seat	NBR	EPDM	FKM
4	Gasket	NBR	EPDM	FKM

WAFER SWING CHECK VALVE


SIZE BETWEEN PN16 FLANGES TYPES (in mm) :



Ref.	DN	40	50	65	80	100	125	150	200	250	300	350	400	450	500	600
351 364 / 365	E	14	14	14	14	18	18	20	22	26	32	38	44	50	56	62
	$\varnothing De$	94	109	129	144	164	194	220	275	331	386	446	497	557	619	736
	$\varnothing P$	22	32	40	54	70	92	112	154	192	227	270	315	358	410	490
	$\varnothing d2$	73.5	84.5	104.5	112.5	140.5	164.5	193.5	249.5	295.5	314.5	387	437	488	536	632
	$\varnothing D2$	3.5	3.5	3.7	3.7	3.7	3.5	3.7	3.7	3.5	6	8	8	8	8	8
	$\varnothing d1$	26.5	36.5	49.5	62	76.5	97.5	118.5	163.5	202.5	242	285	330	377	428	512
	$\varnothing D1$	2.35	2.35	2.7	2.7	3.7	3.5	3.5	3.5	3.5	6	8	8	8	8	8
351 / 364	Weight (in Kg)	0.69	0.86	1.2	1.49	2.42	3.29	4.72	7.92	13.73	21.04	31.5	47	70	96	135
365	Weight (in Kg)	0.68	0.9	1.27	1.53	2.47	3.42	4.8	8.7	14.03	25.1	31.5	47	70	96	135

WAFER SWING CHECK VALVE

SIZE BETWEEN PN10 FLANGES TYPES (in mm) :



DN	400	450
E	44	50
$\varnothing De$	491	541
$\varnothing P$	315	358
$\varnothing d2$	437	488
$\varnothing D2$	8	8
$\varnothing d1$	330	377
$\varnothing D1$	8	8
Weight (in Kg)	47	70
Ref.	365401	365451

WAFER SWING CHECK VALVE

STANDARDS :

Fabrication according to ISO 9001: 2008

Designing according to API 594

Pressure tests according to API 598, table 6


DIRECTIVE 97/23/CE : Products excluded (article 1, § 3-2)

Length according to EN 558 series 97 (NF 29377)


Between flanges according to EN 1092-1 PN10/16

INSTALLATION POSITIONS :

Vertical position (ascendant fluid)



Horizontal position



ADVICE : Our opinion and our advice are not guaranteed and SFERACO shall not be liable for the consequences of damages.
The customer must check the right choice of the products with the real service conditions.

WAFER SWING CHECK VALVE

INSTALLATION INSTRUCTIONS

GENERAL GUIDELINES :

Ensure that the check valves to be used are appropriate for the conditions of the installation (type of fluid, pressure and temperature).

Be sure to have enough valves to be able to isolate the sections of piping as well as the appropriate equipment for maintenance and repair.

Ensure that the valves to be installed are of correct strength to be able to support the capacity of their usage.

INSTALLATION INSTRUCTIONS :

Before installing the check valves, clean and remove any objects from the pipes (in particular bits of sealing and metal) which could obstruct and block the valves.

Ensure that both connecting pipes either side of the check valve (upstream and downstream) are aligned (if they're not, the valves may not work correctly).

Make sure that the two sections of the pipe (upstream and downstream) match, the check valve unit will not absorb any gaps. Any distortions in the pipes may affect the tightness of the connection, the working of the check valve and can even cause a rupture. To be sure, place the kit in position to ensure the assembling will work.

Make sure there is enough space so that the disc can be opened totally in the pipe.

If there is a direction changing or if there's another material, it's better to take away the check valve so that it is outside the turbulence area (**between 3 and 5 times the ND before and after**).

After a pump please refer to FD CEN/TR 13932 standard to install the check valve.